

CLASSIFICATION REPORT REACTION TO FIRE OF A MATERIAL

According to the decree of November 21, 2002 amended relating to the reaction to fire
of construction and installation products

Pilot laboratory recognized by the Ministry of the Interior (decree of February 5, 1959, amended)

Seule la version française fait foi

Only the French version is legally acceptable

No. RA14-0059

Valid 5 years from March 31st, 2014

Requested by: CLEAR FOCUS Imaging, Inc.
60 Maxwell Court
SANTA ROSA, CA 95401
UNITED STATES

Commercial brand: ImageVue 1540
ClassicVue 1550
SuperVue 2050

Brief description:

Micro perforated self-adhesive soft films made of polyvinyl chloride tested on 6 mm thick simple glass substrate.

Overall measured weights per unit area: about 136 g/m² for the "SuperVue 2050" reference, about 132 g/m² for the "ClassicVue 1550" reference and about 151 g/m² for the "ImageVue 1540" reference.

Overall nominal thickness: 180 µm.

Aspect: micro perforated (from 50 to 60 % of printed area).

Colours: white (visible side) and black (adhesive side).

Nature of the test: Test by radiation

Classification: **M1** valid laminated on glass substrate

Durability of the classification (Appendix 2 - Paragraph 5): Non-limited a priori.

Considering the criteria resulting from the tests described in the appended Test Report No. RA14-0059.

The indicated classification does not prejudice the conformity of marketed materials with the samples submitted to the tests and under no circumstances, this document should not be considered as type approval or certification of the product in the sense of the L 115-27 article of the consumption code and the law dated of June 3, 1994.

Champs-sur-Marne, March 31st, 2014

The Head of Laboratory
Responsible for the test



Nicolas ROURE

The reproduction of this classification report is only authorised in its integral form, with or without its test report attached

CENTRE SCIENTIFIQUE ET TECHNIQUE DU BATIMENT

SIÈGE SOCIAL > 84 AVENUE JEAN JAURÈS | CHAMPS-SUR-MARNE | 77447 MARNE-LA-VALLÉE CEDEX 2

TÉL. (33) 01 64 68 84 12 | FAX. (33) 01 64 68 84 79 | www.cstb.fr

MARNE-LA-VALLÉE | PARIS | GRENOBLE | NANTES | SOPHIA-ANTIPOLIS