

## CLASSIFICATION REPORT REACTION TO FIRE OF A MATERIAL

According to the decree of November 21, 2002 amended relating to the reaction to fire  
of construction and installation products

Pilot laboratory recognized by the Ministry of the Interior (decree of February 5, 1959, amended)

Seule la version française fait foi

Only the French version is legally acceptable

**No. RA14-0060**

Valid 5 years from March 31<sup>st</sup>, 2014

**Requested by:** CLEAR FOCUS Imaging, Inc.  
60 Maxwell Court  
SANTA ROSA, CA 95401  
UNITED STATES

**Commercial brand:** PromoVue 1540  
BudgetVue 1533

### Bref description:

Micro perforated self-adhesive soft films made of polyvinyl chloride tested on 6 mm thick simple glass substrate.

Overall measured weights per unit area: about 108 g/m<sup>2</sup> for the "BudgetVue 1533" reference and about 137 g/m<sup>2</sup> for the "PromoVue 1540" reference.

Overall nominal thicknesses: 100 µm for the "BudgetVue 1533" reference and 140 µm for the "PromoVue 1540" reference.

Aspect: micro perforated (from 60 to 67 % of printed area).

Colours: white (visible side) and black (adhesive side).

**Nature of the test:** Test by radiation

**Classification:**

**M1** valid laminated on glass substrate

**Durability of the classification (Appendix 2 - Paragraph 5):** Non-limited a priori.

Considering the criteria resulting from the tests described in the appended Test Report No. RA14-0060.

The indicated classification does not prejudge the conformity of marketed materials with the samples submitted to the tests and under no circumstances, this document should not be considered as type approval or certification of the product in the sense of the L 115-27 article of the consumption code and the law dated of June 3, 1994.

Champs-sur-Marne, March 31<sup>st</sup>, 2014

The Head of Laboratory  
Responsible for the test



Nicolas ROURE

The reproduction of this classification report is only authorised in its integral form, with or without its test report attached

**CENTRE SCIENTIFIQUE ET TECHNIQUE DU BATIMENT**

SIÈGE SOCIAL > 84 AVENUE JEAN JAURÈS | CHAMPS-SUR-MARNE | 77447 MARNE-LA-VALLÉE CEDEX 2

TÉL. (33) 01 64 68 84 12 | FAX. (33) 01 64 68 84 79 | [www.cstb.fr](http://www.cstb.fr)

MARNE-LA-VALLÉE | PARIS | GRENOBLE | NANTES | SOPHIA-ANTIPOLIS